



March 6, 2014

GREATENS SEPTIC SERVICE, INC.
GALE GREATENS
3483 KEWAUNEE RD.
GREEN BAY WI 54311

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: GREATENS SEPTIC SERVICE, INC.
Product Name: SEPTIC, PUMP OR GREASE INTERCEPTOR
Model Number(s): 1000
(36.5" L.L., 27.4 GAL/IN., 48" MAX. DEPTH OF BURY, ACTUAL CAPACITY 1061.8 GALS.,
479 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL
FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 120 IN. L X 68 IN. W X
49.5 IN. H)
Product File No: 20140030

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.**

This approval supersedes the approval issued on 1/28/2009 under product file number 20090037.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- The products produced by this manufacturer are approved to use the following:
 - One-inch schedule 40 PVC cast in riser for electrical wiring.
 - Bottom openings for holding tank and for pump tank or compartment.
 - Department approved effluent filter designed installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Access opening cover with 4-inch opening.
 - Press Seal "Cast-A-Seal" by Press Seal Gasket Corp.
 - Department approved plastic risers and covers.

GREATENS SEPTIC SERVICE, INC.

Page 2

March 6, 2014

Product File No: 20140030

- Bedding: tank shall be placed with a min. of 3 in. sand pad or gravel.
- When used as septic or pump tank, Best GF 10-8 filter or equivalent may be installed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov